

## Laboratory Inspection Notice

## The following safety concerns were noted during recent inspection of facilities

LABORATORY ROOM #			 	 	 	
EQUIPMENT						
29 CFR 1910.151(c)						
(eyewash/showers)						
29 CFR 1910.212						
(machine guarding)						
NFPA 45 8.13.2						
(fume hood inoperable)						
NFPA 45 12.2.2.1						
(refrigerator labeled)						
NFPA 45 5.6						
(electrical)						
GAS CYLINDERS						
NFPA 45 11.1.5.1						
(unsecured)						
NFPA 45 13.3.1						
(labeling)						
NFPA 45 11.1.6.4						
(not in-use storage)						
FLAMMABLE LIQUIDS						
NFPA 45 9.2.2.6						
(excessive quantities)						
NFPA 45 9.2.3.3						
( Class I&II proper storage)						
CHEMICALS						
NFPA 45 9.2.3.4						
(time sensitive hazard)						
NFPA 45 9.2.3.7						
(fume hood storage)						
29 CFR 1910.141						
(stored with food/drink)						
NFPA 45 9.2.3.2						
(segregation)						
29 CFR 1910.1450						
(hazardous chemicals in lab)						
NFPA 45 13.3.1						
(labeling)						
NFPA 45 9.2.2.7						
(improper storage)						
FACILITIES						
29 CFR 1910.22(a)						
(housekeeping)						
29 CFR 1910.37						
(means of egress)						
29 CFR 1910.22(b)						
(aisles)						

COMMENTS

The preceding safety concerns are deficiencies of the Radford University Chemical Hygiene Plan, NFPA, and OSHA regulations; and are subject to immediate correction. A re-inspection to determine compliance with this notice will be conducted in 30 days. Your cooperation in resolving these deficiencies is greatly appreciated.

Inspector

Manager/ Supervisor